

To All Teamleaders

Date:- 15 May 1993

Subject :- Am Service

The hospital is at present allowing contractors to install security cameras around the site. This company performing the operation has already caused damage around the site and have gained access to these premises without our permission. An installation has been made by them and also they have damaged ceiling tiles.

A discussion took place this week between the senior management of the radio station and the works dept with the outcome that they are to remove their fitting from these premises.

Saturday 15 May

On this day I came up to repair the studio two lights; which has been done, I also noticed that cable two output of the medium wave service has blown a fuse. We don't know when this was done but It might be just coincidence that it happens as these other contractors are on site.

We are now without service to all of Special care baby unit and all the out-patient departments.

Tim Foulsham of Wireless Workshop cannot get here until Thursday 20th May to look at what's wrong.

In the meantime before you go out on the wards check the cable driver on the unit and ensure that the three remaining lights are lit. If for any reason they are not: Do not go out on the wards until you have phoned me to let me know.

You might end up broadcasting to yourselves.

Regards

P.J.

Place this notice on the following nights team clip